

Who is the emergency contact for each? Is there someone we can call if we need information regarding emergency situations in addition to the emergency numbers?

877-860-6020 Opt.9 (Gas Leaks/ Related Emergencies)

0700-1800 A representative will collect the incident information from the caller, create the Emergency Response Order, and Dispatch will route the appropriate resources to the incident based on our response matrix.

1800-0700 Afterhours Dispatch will collect the incident information from the caller and create the Emergency Response Order and route the appropriate resources to the incident based on our response matrix.

Notifications will be made to appropriate SWG management personnel via Everbridge application platform.

What is the email address the jurisdictions need to send E-tag and Gas Tag approvals to?

[GasInspectionTag@swgas.com](mailto:GasInspectionTag@swgas.com)

Do these approvals expire?

The inspections are good for 180 days.

From City of Las Vegas: Does the report for E-tags and gas tags need to show the tag number? We have been told yes and no.

We just need them to say it's passed, and we look for the email address it came from to make sure it is legit.

Does NVEnergy need the tag identified as temporary or permanent power?

(CNLV does not include tag numbers)

City of Las Vegas sends a daily demo report to LVVWD and SWG, is this report still needed?

Yes. Please be sure they are emailed to [SNV-N-Construction@swgas.com](mailto:SNV-N-Construction@swgas.com)

With the push for all electric communities and potential increases for electric vehicle charging does NVEnergy see any issues or requirements to ensure the electrical network can handle the increase? Or any future regulations we need to be aware of?

LVVWD: Any major upcoming changes in regulations that would impact the industry, for example pool restrictions, due to water shortage issues.

Our Industry members would like to know how the processes differ for each jurisdiction.

SWG works diligently to ensure all our business process, policies and procedures are maintained and practiced equitably with all jurisdictions.

Linda Gallant

PE to Steel transitions on riders – We are noticing an increased number of approved inspections on underground gas lines installations to outdoor gas features (Pool Heater, BBQ's, Fireplaces/Pits, etc.) where the PE to steel transitions is occurring at or above finished grade.